



494551

Nº 108073

County Shark Township Canton Section of Township _____
or Lot Number _____
Owner _____ Address _____
Location of property _____

PUMPING TEST

Pumping rate 20 G.P.M. Duration of test _____ hrs.
 Drawdown _____ ft. Date July 27, 1953
 Developed capacity 20 g.p.m.
 Static level—depth to water 55' ft.
 Pump installed by _____

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

sand & gravel

0 Feet

71.4 Ft.

N.

W.

E

S

See reverse side for instructions

Date July 30 1953

Signed D. Mc Hall

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

Location of property San Francisco, California

***If additional space is needed to complete well log, use next consecutive numbered form.**

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER

DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES

Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

Nº 349463

County St. Louis Township 24 Section of Township 1

Owner [REDACTED]

Location of property [REDACTED]

CONSTRUCTION DETAILS

Casing diameter 11" Length of casing 109'
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

BAILING OR PUMPING TEST

Pumping Rate _____ G.P.M. Duration of test _____ hrs.
Drawdown NONE ft. Date _____
Static level-depth to water 78 ft.
Quality (clear, cloudy, taste, odor) clear
Pump installed by _____

WELL LOG*

| Formations Sandstone, shale, limestone, gravel and clay | From | To |
|---|---------------|---------------|
| <u>Brown Sand & Gravel</u> | <u>0 Feet</u> | <u>20 Ft.</u> |
| <u>Hard Sand & Gravel</u> | <u>20'</u> | <u>35'</u> |
| <u>Crumbly Sand & Gravel</u> | <u>35'</u> | <u>60'</u> |
| <u>Hard Sand & Gravel</u> | <u>60'</u> | <u>67'</u> |
| <u>Brown Sand & Gravel</u> | <u>67'</u> | <u>100'</u> |
| <u>Gray Sand</u> | <u>100'</u> | <u>110'</u> |
| <u>Limestone</u> | <u>110'</u> | <u>111'</u> |
| <u>Gray Shale</u> | <u>111'</u> | <u>116'</u> |
| | | |
| | | |
| | | |
| | | |
| | | |

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

W.

See reverse side for instructions

Drilling Firm George L. [REDACTED]

Date 6-18-1966

Signed George L. [REDACTED]

*If additional space is needed to complete well log, use next consecutive numbered form.

WELL LOG AND DRILLING REPORT

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1500 Dublin Road
Columbus, Ohio

No. 206937

County Stark Township Stanton Section of Township 19

CONSTRUCTION DETAILS

Casing diameter 4" Length of casing 141'
Type of screen..... Length of screen.....
Type of pump.....
Capacity of pump.....
Depth of pump setting.....
Date of completion.....

BAILING OR PUMPING TEST

Pumping rate 10 G.P.M. Duration of test 2 hrs.
Drawdown none ft. Date Nov. 12, 1957
Developed capacity.....
Static level—depth to water 20 ft.
Pump installed by.....

WELL LOG

| Formations Sandstone, shale, limestone, gravel and clay | From | To |
|---|--------|--------|
| sand, gravel | 0 Feet | 20 Ft. |
| light clay | 20 | 90 |
| fine gravel | 90 | 120 |
| light clay | 120 | 137 |
| dark shale | 137 | 140 |
| light sandy shale | 140 | 151 |
| No iron 13 gr. hardness | | |

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N

W

S.

See reverse side for instructions

Date Nov. 14, 1957 h. On

Signed John A. Adams

Drilling Firm [REDACTED]

Address [REDACTED]

ORIGINAL

559732

LOCATI

*If additional space is needed to complete well log, use next consecutive numbered form.

rmit #22136

Columbus, Ohio

Stark

Township

Canton

Section of Township

19

CONSTRUCTION DETAILS

g diameter 5" Length of casing 62'
 of screen _____ Length of screen _____
 of pump _____
 city of pump _____
 h of pump setting _____
 of completion _____

 BAILING OR PUMPING TEST
 (Specify one by circling)

Test Rate 10 G.P.M. Duration of test 1 hrs.
 Drawdown none ft. Date 7/11/73
 Static level-depth to water 36 ft.
 Quality (clear, cloudy, taste, odor) clear
 Pump installed by _____

WELL LOG*

| Formations | From | To |
|--|--------|--------|
| Sandstone, shale, limestone, gravel and clay | | |
| sand, gravel | 0 Feet | 56 Ft. |

perforated point

SKETCH SHOWING LOCATION

Locate in reference to numbered
 State Highways, St. Intersections, County roads, etc.

N.

W.

S.

Drilling Firm

Address

Date

7/17/73

Signed



LOCATED

37

*If additional space is needed to complete well log, use next consecutive numbered form.

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus 12, Ohio

No 281361

County STARK Township CANTON Section of Township _____

CONSTRUCTION DETAILS

Casing diameter 1 1/2" Length of casing 72'
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

BAILING OR PUMPING TEST

Pumping Rate 18 G.P.M. Duration of test 1 1/2 hrs.
Drawdown NONE ft. Date 5-9-62
Static level-depth to water 72 ft.
Quality (clear, cloudy, taste, odor) CLEAR
Pump installed by _____

WELL LOG

| Formations Sandstone, shale, limestone, gravel and clay | From | To |
|---|---------------|---------------|
| <u>CLACIAL</u> | <u>0 Feet</u> | <u>21 Ft.</u> |
| <u>GRAVEL</u> | <u>21</u> | <u>41</u> |
| <u>MUD</u> | <u>41</u> | <u>61</u> |
| <u>SAND & GRAVEL</u> | <u>61</u> | <u>74</u> |
| <u>SHALE</u> | <u>74</u> | <u>81</u> |
| <u>LIME</u> | <u>81</u> | <u>84</u> |
| <u>SHALE</u> | <u>84</u> | <u>98</u> |

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

W.

S.

See reverse side for instructions

Drilling Firm KENNETH WHITE SONS

Address _____

Date MAY 9, 1962

Signed _____

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

No. 396009

County Stark Township Panton Section of Township _____

CONSTRUCTION DETAILS

Casing diameter 4 1/2 Length of casing 81
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

BAILING OR PUMPING TEST (Specify one by circling)


Test Rate 15 G.P.M. Duration of test 1 hrs.
Drawdown 12 ft. Date 6-20-69
Static level-depth to water 47 ft.
Quality (clear, cloudy, taste, odor) Clear
Pump installed by _____

WELL LOG*

| Formations Sandstone, shale, limestone, gravel and clay | From | To |
|---|---------------|---------------|
| <u>Sand-gravel</u> | <u>0 Feet</u> | <u>62 Ft.</u> |
| <u>Soft shale</u> | <u>62</u> | <u>89</u> |
| <u>Grey shale</u> | <u>79</u> | <u>96</u> |
| <u>Concreted</u> | <u>96</u> | <u>99</u> |
| <u>Grey shale</u> | <u>99</u> | <u>104</u> |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



Date 6-20-69
Signed J. Skelton

*If additional space is needed to complete well log, use next consecutive numbered form.

Nº 336715

County Stark Township Caston Section of Township 19

BAILING OR PUMPING TEST

Pumping Rate 10 G.P.M. Duration of test 1 1/2 hrs.
Drawdown 10 ft. Date 12/24/55
Static level-depth to water 50 ft.
Quality (clear, cloudy, taste, odor) Clear

Pump installed by _____

SKETCH SHOWING LOCATION

N.

[illegible]

W.

3

S.

See reverse side for instructions

Date 12/20/63

Signed W. J. Wilson

*If additional space is needed to complete well log, use next consecutive numbered form.

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
OHIO WATER RESOURCES BOARD
Department of Public Works
553 E. Broad St., Columbus 15, Ohio

No 73057

Cannon

County Stark Township Canton Section of Township
or Lot Number 19

CONSTRUCTION DETAILS

Casing diameter 4" Length of casing 184'
Type of screen — Length of screen —
Type of pump —
Capacity of pump —
Depth of pump setting —

PUMPING TEST


Pumping rate — G.P.M. Duration of test — hrs.
Drawdown 3 ft. Date 4-4-50
Developed capacity 7 gpm
Static level of completed well 72 ft.
Pump installed by —

WELL LOG

| Formations Sandstone, shale, limestone, gravel and clay | From | To |
|---|--------|---------|
| Wash formation | 0 Feet | 176 Ft. |
| gray shale - soft | 176 | 180 |
| sandrock | 180 | 198 |
| dark shale | 198 | 208 |
| sandrock | 208 | 226 |
| Water at 183' to 200' | | |

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



S.

See reverse side for instructions

Drilling Firm Everett Walte & Co.Date 4-6-50

Address

Signed

A. D. Carr